



UNITED STATES PATENT AND TRADEMARK OFFICE

UNITED STATES DEPARTMENT OF COMMERCE
United States Patent and Trademark Office
Address: COMMISSIONER FOR PATENTS
P.O. Box 1450
Alexandria, Virginia 22313-1450
www.uspto.gov

APPLICATION NO.	FILING DATE	FIRST NAMED INVENTOR	ATTORNEY DOCKET NO.	CONFIRMATION NO.
10/719,163	11/21/2003	Randy J. Longsdorf	R11.12-0812	2356

27367 7590 01/10/2006

WESTMAN CHAMPLIN & KELLY, P.A.
SUITE 1400 - INTERNATIONAL CENTRE
900 SECOND AVENUE SOUTH
MINNEAPOLIS, MN 55402-3319

EXAMINER

CHANG, SUNRAY

ART UNIT PAPER NUMBER

2121

DATE MAILED: 01/10/2006

Please find below and/or attached an Office communication concerning this application or proceeding.

Office Action Summary	Application No. 10/719,163	Applicant(s) LONGSDORF ET AL.	
	Examiner Sunray Chang	Art Unit 2121	

-- The MAILING DATE of this communication appears on the cover sheet with the correspondence address --
Period for Reply

A SHORTENED STATUTORY PERIOD FOR REPLY IS SET TO EXPIRE 3 MONTH(S) OR THIRTY (30) DAYS, WHICHEVER IS LONGER, FROM THE MAILING DATE OF THIS COMMUNICATION.

- Extensions of time may be available under the provisions of 37 CFR 1.136(a). In no event, however, may a reply be timely filed after SIX (6) MONTHS from the mailing date of this communication.
- If NO period for reply is specified above, the maximum statutory period will apply and will expire SIX (6) MONTHS from the mailing date of this communication.
- Failure to reply within the set or extended period for reply will, by statute, cause the application to become ABANDONED (35 U.S.C. § 133). Any reply received by the Office later than three months after the mailing date of this communication, even if timely filed, may reduce any earned patent term adjustment. See 37 CFR 1.704(b).

Status

- 1) ☒ Responsive to communication(s) filed on 21 November 2003.
- 2a) ☐ This action is FINAL. 2b) ☒ This action is non-final.
- 3) ☐ Since this application is in condition for allowance except for formal matters, prosecution as to the merits is closed in accordance with the practice under *Ex parte Quayle*, 1935 C.D. 11, 453 O.G. 213.

Disposition of Claims

- 4) ☒ Claim(s) 1-55 is/are pending in the application.
- 4a) Of the above claim(s) _____ is/are withdrawn from consideration.
- 5) ☐ Claim(s) _____ is/are allowed.
- 6) ☒ Claim(s) 1-55 is/are rejected.
- 7) ☐ Claim(s) _____ is/are objected to.
- 8) ☐ Claim(s) _____ are subject to restriction and/or election requirement.

Application Papers

- 9) ☐ The specification is objected to by the Examiner.
- 10) ☒ The drawing(s) filed on 21 November 2003 is/are: a) ☒ accepted or b) ☐ objected to by the Examiner.
Applicant may not request that any objection to the drawing(s) be held in abeyance. See 37 CFR 1.85(a).
Replacement drawing sheet(s) including the correction is required if the drawing(s) is objected to. See 37 CFR 1.121(d).
- 11) ☐ The oath or declaration is objected to by the Examiner. Note the attached Office Action or form PTO-152.

Priority under 35 U.S.C. § 119

- 12) ☐ Acknowledgment is made of a claim for foreign priority under 35 U.S.C. § 119(a)-(d) or (f).
- a) ☐ All b) ☐ Some * c) ☐ None of:
1. ☐ Certified copies of the priority documents have been received.
2. ☐ Certified copies of the priority documents have been received in Application No. _____.
3. ☐ Copies of the certified copies of the priority documents have been received in this National Stage application from the International Bureau (PCT Rule 17.2(a)).
- * See the attached detailed Office action for a list of the certified copies not received.

Attachment(s)

- | | |
|---|---|
| 1) <input checked="" type="checkbox"/> Notice of References Cited (PTO-892) | 4) <input type="checkbox"/> Interview Summary (PTO-413)
Paper No(s)/Mail Date. _____ |
| 2) <input type="checkbox"/> Notice of Draftsperson's Patent Drawing Review (PTO-948) | 5) <input type="checkbox"/> Notice of Informal Patent Application (PTO-152) |
| 3) <input checked="" type="checkbox"/> Information Disclosure Statement(s) (PTO-1449 or PTO/SB/08)
Paper No(s)/Mail Date _____ | 6) <input type="checkbox"/> Other: _____ |

Art Unit: 2121

DETAILED ACTION

1. This office action is in responsive to the paper filed on November 21st, 2003.

Claims 1 – 55 are presented for examination.

Claims 1 – 55 are rejected.

Claim Rejections - 35 USC § 103

The following is a quotation of 35 U.S.C. 103(a) which forms the basis for all obviousness rejections set forth in this Office action:

(a) A patent may not be obtained though the invention is not identically disclosed or described as set forth in section 102 of this title, if the differences between the subject matter sought to be patented and the prior art are such that the subject matter as a whole would have been obvious at the time the invention was made to a person having ordinary skill in the art to which said subject matter pertains. Patentability shall not be negated by the manner in which the invention was made.

The factual inquiries set forth in *Graham v. John Deere Co.*, 383 U.S. 1, 148 USPQ 459 (1966), that are applied for establishing a background for determining obviousness under 35 U.S.C. 103(a) are summarized as follows:

1. Determining the scope and contents of the prior art.
2. Ascertaining the differences between the prior art and the claims at issue.
3. Resolving the level of ordinary skill in the pertinent art.
4. Considering objective evidence present in the application indicating obviousness or nonobviousness.

2. **Claims 1 – 8, 10 – 12, 15 – 42, 44, 45, 47 – 55 are rejected** under 35 U.S.C. 103(a) as being unpatentable over Evren Eryurek (U.S. Patent No. 6,017,143 and referred to as **Eryurek** hereinafter), and in view of Edward R. Sederlund et al. (U.S. Patent No. 6,647,301 and referred to as **Sederlund** hereinafter).

(**Eryurek** as set forth above generally discloses the basic inventions.)

Regarding independent claims 1, 36 and 37,

Eryurek teaches,

- A transmitter for use in an industrial process, [Col. 3, Lines 9 – 12] comprising:
- a sensor module [16, Fig. 1] configured to couple to the process and measure a process variable; [Col. 3, Lines 9 – 12]
- a feature module configured to couple to the sensor module, [Abstract, Col. 1, Lines 44 – 64; and Fig. 1] the feature module including:
- a device interface configured to couple to the process device [Abstract] and provide an output related to operation of a component of the process device; [an input which receives a process signal, Col. 1, Lines 44 – 45]
- a component monitor configured to monitor operation of the component based upon the output from the device interface and identify a safety event of the component; [Col. 8, Line 30 – Col. 9, Line 14; computing circuitry provides an event output ... in response to, Col. 1, Lines 53 – 57; provide an event output, Col. 1, Line 44 – 64; rules are selected to detect events, Col. 1, Lines 44 – 64] and
- a safety response module configured to respond to the safety event of the component in accordance with a safety response. [Col.. 6, Lines 21 – 42; provide an event output, Col. 1, Line 44 – 64; rules are selected to detect events, Col. 1, Lines 44 – 64]

Eryurek does not teach Safety Integrity Level (SIL).

Art Unit: 2121

Sederlund teaches Safety Integrity Level (SIL) [Abstract, Col. 1, Lines 14 – 17; Col. 2, Lines 45 – 50; Col. 9, Lines 31 – 61; Col. 12, 12 – 60; Col. 22, Line 52 – Col. 24, Line 10] for the purpose of providing a rule set [Col. 12, Lines 12 – 60].

It would have been obvious to a person of ordinary skill in the art at the time of applicant's invention to modify the teaching of **Eryurek** to include "Safety Integrity Level (SIL)" for the purpose of providing a rule set [Col. 12, Lines 12 – 60].

Regarding dependent claim 2,

Eryurek teaches, the apparatus of claim 1 wherein the device interface comprises

- a connection to a databus of the process device. [Col. 2, Line 65 – Col. 3, Line 33; Fig. 1]

Further explanation, The term, "databus", has been interpreted to as "2-wire process control loop" based on the definition in specification [Page 16, Line 29; Page 17, Lines 1 – 12, and 21; Fig. 3 and Fig. 1]

Regarding dependent claims 3, 21, 28 and 38,

Eryurek teaches, an apparatus wherein

- the component monitor is configured to monitor data carried on the databus. [monitors the process and performs computations, Col. 3, Lines 22 – 25; Col. 8, Line 30 – Col. 9, Line 14]

Regarding dependent claim 4,

Eryurek teaches, the apparatus of claim 1 wherein the device interface comprises

- a sensor coupled to the process device. [16, Fig. 1; sensor, Col. 3, Lines 9 – 12; Col. 4, Lines 35 – 42]

Regarding dependent claims 5 and 40,

Eryurek teaches, an apparatus wherein

- the process device couples to a process control loop and sensor is configured to monitor current flow in the process control loop. [diagnostic signal sensed by sensor, Col. 4, Lines 38 – 42; diagnostic signals include ... electrical voltage, current ... Col. 2, Lines 46 – 57]

Regarding dependent claims 6 and 41,

Eryurek teaches, an apparatus wherein

- the component monitor compares the sensed current with a current value. [diagnostic signal sensed by sensor, Col. 4, Lines 38 – 42; diagnostic signals include ... electrical voltage, current ... Col. 2, Lines 46 – 57; determines faulty, Col. 8, Lines 42 – 44]

Regarding dependent claims 7 and 42,

Eryurek teaches, an apparatus wherein

- the safety response module controls the current in a process control loop based upon a safety failure. [diagnostic signal sensed by sensor, Col. 4, Lines 38 – 42; diagnostic signals include

Art Unit: 2121

... electrical voltage, current ... Col. 2, Lines 46 – 57; determines faulty, Col. 8, Lines 42 – 44; statistical parameter mean, current means, Col. 6, Lines 21 – 42]

Regarding dependent claim 8,

Eryurek teaches, the apparatus of claim 1, the device interface

Sederlund teaches a watch dog circuit [Col. 7, Lines 19 – 20; Fig. 35].

Regarding dependent claim 10,

Eryurek teaches, the apparatus of claim 1, wherein

- the device interface couples to a memory. [input, memory, Col. 1, Lines 44 – 46]

Regarding dependent claims 11 and 44,

Eryurek teaches, an apparatus, wherein

- the component monitor is configured to detect errors in the data stored in the memory. [Col. 8, Line 42 – Col. 9, Line 10]

Regarding dependent claims 12 and 45,

Eryurek teaches, an apparatus, wherein

- the safety response module provides an alarm output. [alarm is sounded, Col. 1, Lines 34 – 35]

Art Unit: 2121

Regarding dependent claims 15 and 47,

Eryurek teaches, an apparatus, wherein

- the safety response module attempts to compensate for the safety failure. [defines the acceptable variations, Col. 6, Lines 21 – 42]

Regarding dependent claims 16 and 48,

Eryurek teaches, an apparatus, wherein

- the safety response module corrects for errors in data in the device. [adjusted by adjusting the sensitivity parameter, Col. 6, Lines 56 – 59]

Regarding dependent claim 17,

Eryurek teaches, the apparatus of claim 16, wherein

- the safety response module interpolates between data points in order to correct a data error.
[adjusting value by changing the flow in pipe, Col. 3, Lines 15 – 33]

Regarding dependent claim 18,

Eryurek teaches, the apparatus of claim 16, wherein

- the safety response module holds a previous data point. [Col. 5, Lines 51 – 53]

Art Unit: 2121

Regarding dependent claims 19 and 49,

Eryurek teaches, an apparatus, wherein

- the sensor comprises a voltage sensor. [electrical voltage ... or any parameter ... maybe detected, Col. 2, Lines 42 – 64]

Regarding dependent claims 20 and 50,

Eryurek teaches, an apparatus, wherein

- a current sensor. [current ... or any parameter ... maybe detected, Col. 2, Lines 42 – 64]

Regarding dependent claim 22,

Eryurek teaches, the apparatus of claim 1 wherein the component monitor comprises

- software implemented in a microprocessor of the device. [Col. 10, Lines 2 – 5]

Regarding dependent claims 23 and 51,

Eryurek teaches, an apparatus wherein the safety event comprises

- a possibility of a future component failure. [exceed predefined limits, Col. 1, Lines 34 – 36]

Regarding dependent claims 24 and 52,

Eryurek teaches, an apparatus wherein the safety event comprises

- a detection of a component failure. [faulty device, Col. 9, Lines 43 – 45]

Regarding dependent claims 25 and 53,

Eryurek teaches a process variable transmitter including the apparatus of claim 1. [12, Fig. 1]

Regarding dependent claim 26,

Eryurek teaches the transmitter of claim 25 wherein

- the safety response module is implemented in a feature module which couples to a sensor module. [Fig. 2 and Col. 10, Lines 2 – 5]

Regarding dependent claim 27,

Eryurek teaches the transmitter of claim 25 wherein

- the safety response module is implemented in a feature module which couples to a plurality of sensor modules. [Fig. 2 & Col. 10, Lines 2 – 5 & Col. 8, Lines 65 – 66]

Regarding dependent claim 29,

Eryurek teaches the apparatus of claim 25 including

- a display and wherein the component monitors data sent to the display. [a display, Col. 4, Lines 44 – 58]

Regarding dependent claim 30,

Eryurek teaches a process controller including the apparatus of claim 1. [Fig. 1]

Art Unit: 2121

Regarding dependent claims 31 and 54,

Eryurek teaches a device in a Safety Instrumented System (SIS) in accordance with claim 1. [Col. 1, Lines 34 – 41]

Regarding dependent claim 32,

Eryurek teaches the apparatus of claim 1 wherein

- the component monitor is configured to monitor a plurality of process devices. [Col. 3, Lines 34 – 36; 208, Fig. 6]

Regarding dependent claim 33,

Eryurek teaches the apparatus of claim 1 wherein

- the component monitor and safety response module are implemented in software. [Col. 10, Lines 2 – 5]

Regarding dependent claims 34 and 55,

Eryurek teaches an apparatus wherein

- the software is configured to upgrade an existing process device.

Regarding dependent claim 35,

Eryurek teaches,

- a feature module configured to upgrade an existing process device. [Col. 9, Line 65 – Col. 10, Line 10]

Regarding dependent claim 39,

Eryurek teaches, the method of claim 37 wherein

- the sensing uses a sensor coupled to the process device. [Col. 3, Lines 9 – 12]

3. **Claims 9 and 43 are rejected** under 35 U.S.C. 103(a) as being unpatentable over **Eryurek** in view of **Sederlund**, and further in view of Paul J. Hays et al. (U.S. Patent No. 6,476,522 and referred to as **Hays** hereinafter).

Regarding dependent claims 9 and 43,

Eryurek teaches, an apparatus with a device interface [Abstract, Col. 1, Lines 44 – 45]

Hays teaches sense power drawn by circuitry of the process device. [electronic components for controlling power drawn by a measurement device, Col. 1, Lines 7 – 8 & Abstract] for the purpose of controlling power drawn [Col. 1, Lines 7 – 8]

4. **Claims 13, 14 and 46 are rejected** under 35 U.S.C. 103(a) as being unpatentable over **Eryurek** in view of **Sederlund**, and further in view of Gordon M. Sommer (U.S. Patent No. 4,356,900 and referred to as **Sommer** hereinafter).

Regarding dependent claims 13, 14 and 46,

Eryurek teaches, an apparatus with a device interface [Abstract, Col. 1, Lines 44 – 45]

Art Unit: 2121

Sommer teaches the safety response module disconnects the process device from a process control loop. [deactuate the clutch unit so as to disconnect the motor from the driving apparatus in response to abnormal operating conditions, Abstract] for the purpose of safety [Abstract]

Conclusion

5. Any inquiry concerning this communication or earlier communications from the examiner should be directed to Sunray Chang whose telephone number is (571) 272-3682. The examiner can normally be reached on M-F 7:00-4:30.

If attempts to reach the examiner by telephone are unsuccessful, the examiner's supervisor, Anthony Knight can be reached on (571) 272-3687. The fax phone number for the organization where this application or proceeding is assigned is 571-273-8300.

Any inquiry of a general nature or relating to the status of this application or proceeding should be directed to the receptionist whose telephone number is 703-746-3506.

Sunray Chang
Patent Examiner
Group Art Unit 2121
Technology Center 2100
U.S. Patent and Trademark Office

January 5, 2006


Anthony Knight
Supervisory Patent Examiner
Group 3600